

University of Nebraska - Lincoln

DigitalCommons@University of Nebraska - Lincoln

Faculty Publications from the Department of
Electrical and Computer Engineering

Electrical & Computer Engineering, Department
of

2009

Missing-Sensor-Fault-Tolerant Control for SSSC FACTS Device with Real-Time Implementation

Wei Qiao

University of Nebraska–Lincoln, wqiao@engr.unl.edu

Ganesh Venayagamoorthy

Missouri University of Science and Technology

Ronald G. Harley

Georgia Institute of Technology

Follow this and additional works at: <https://digitalcommons.unl.edu/electricalengineeringfacpub>



Part of the [Electrical and Computer Engineering Commons](#)

Qiao, Wei; Venayagamoorthy, Ganesh; and Harley, Ronald G., "Missing-Sensor-Fault-Tolerant Control for SSSC FACTS Device with Real-Time Implementation" (2009). *Faculty Publications from the Department of Electrical and Computer Engineering*. 139.

<https://digitalcommons.unl.edu/electricalengineeringfacpub/139>

This Article is brought to you for free and open access by the Electrical & Computer Engineering, Department of at DigitalCommons@University of Nebraska - Lincoln. It has been accepted for inclusion in Faculty Publications from the Department of Electrical and Computer Engineering by an authorized administrator of DigitalCommons@University of Nebraska - Lincoln.

Missing-Sensor-Fault-Tolerant Control for SSSC FACTS Device with Real-Time Implementation

Wei Qiao¹, Ganesh Venayagamoorthy², Ronald Harley³

¹University of Nebraska-Lincoln, ²Missouri University of Science and Technology, ³Georgia Institute of Technology

Control of power systems relies on the availability and quality of sensor measurements. However, measurements are inevitably subjected to faults caused by sensor failure, broken or bad connections, bad communication, or malfunction of some hardware or software. These faults in turn may cause the failure of power system controllers and consequently severe contingencies in the power system. To avoid such contingencies, this paper presents a sensor evaluation and (missing sensor) restoration scheme (SERS) by using auto-associative neural networks (auto-encoders) and particle swarm optimization (PSO). Based on the SERS, a missing-sensor-fault-tolerant control (MSFTC) is developed for controlling a static synchronous series compensator (SSSC) connected to a power network. This MSFTC improves the reliability, maintainability and survivability of the SSSC and the power network. The effectiveness of the MSFTC is demonstrated by a real-time implementation of an SSSC connected to the IEEE 10-machine 39-bus system on the Real Time Digital Simulator (RTDS) and TMS320C6701 digital signal processor platform. The proposed fault-tolerant control can be readily applied to many existing controllers in power systems.